

Specification for LPG cylinder and its storage, handling and transportation



Guyana National Bureau of Standards

GUYANA STANDARD

Specification for
LPG cylinder and its storage, handling and transportation

INTENDED TO BE MADE COMPULSORY OCTOBER 2026

Guyana National Bureau of Standards

© GNBS 2025

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilised otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from GNBS at the address below.

Guyana National Bureau of Standards (GNBS)

Track MB, Block B

National Exhibition Centre, Sophia

Georgetown, Guyana

Telephone: 592-219-0064-66

Email: standards@gnbsgy.org

Website: www.gnbsgy.org

Standards Portal: www.gnbsguy.com

ICS 23.020.35; 75.160

Contents

Foreword	iii
Members of the Technical Committee - Gas Cylinders	iv
1 Scope	1
2 Definitions	1
3 Cylinder specifications	1
3.1 Containers specifications	1
3.2 Cylinder markings	1
3.3 Connections and appurtenances	2
3.4 Cylinder body	3
3.5 Cylinder repairs	3
3.6 Cylinder requalification	3
3.6.1 Water jacket type hydrostatic test	4
3.6.2 Simple hydrostatic test	4
3.7 Storage location	4
3.8 Outdoor storage	4
3.9 Separation distances	5
3.10 Indoor storage	5
3.11 Cylinder stacking	6
3.12 Fire extinguishers	6
3.13 Cylinders for display	7
4 Handling	7
5 Transportation	7

Foreword

This Guyana Standard was developed and first published in 2005 as **GYS 264:2005, Specification for the Storage, handling and transportation of LPG cylinders**. In the formulation of this standard, assistance was derived from the following publication:

(a) LPG Road Transport Standard. Shell International Petroleum Company Limited. October 2002.

In 2021, the standard's first revision was done and published. In 2025, a review and subsequent second revision was done by the **Technical Committee (TC) – Gas Cylinders**. In this revision, the title of the standard was amended to **GYS 264: 2025, LPG cylinder and its storage, handling and transportation** and the requirements were expounded upon for greater clarity and ease of use.

This standard was developed to establish requirements for the safe use and storage of LPG cylinders and is intended to be made compulsory.

INTENDED TO BE MADE COMPULSORY OCTOBER 2026

Members of the Technical Committee - Gas Cylinders

Name	Affiliation
Mr. Kevon Simon (Chairperson)	Competition and Consumer Affairs Commission
Ms. Karen Watson	Environmental Protection Agency
Ms. Tomara Fiffie (Alternate)	Environmental Protection Agency
Mr. Cary Hutson	Guyana Energy Agency
Mr. Sheldon Sauns	Guyana Fire Service
Mr. Lorenzo Gill	Guyana National Bureau of Standards
Ms. Xuxa Chan	Guyana Revenue Authority
Mr. Navin Rambharose	Guygas Incorporated
Mr. Omindra Persaud (Alternate)	Guygas Incorporated
Mr. Ryan Basdeo	Massy Gas Products (Guyana) Limited
Mr. Zulfiqar Ali (Alternate)	Massy Gas Products (Guyana) Limited
Mr. Darwin Bourne	Ministry of Labour and Manpower Planning
Ms. Jo-Ann Busgith (Technical Secretary)	Guyana National Bureau of Standards

Specification for LPG cylinder and its storage, handling and transportation

1 Scope

This standard outlines the specifications for the storage, handling and transportation of portable containers used for the storage of liquefied petroleum gases (LPG).

2 Definitions

For the purpose of this standard, the following definitions shall apply:

2.1 container

Any vessel, including tanks and cylinders that are used for transporting or storing LPG.

2.2 cylinder

A portable container designed and constructed to contain LPG with a water capacity less than 454kg.

2.3 liquefied petroleum gases (LPG)

Material composed primarily of the following hydrocarbons either by themselves or as mixtures: propane, butane, propylene and butylene.

2.4 tare weight

The weight of the empty cylinder with the valve on.

3 Cylinder specifications

3.1 Containers specifications

Cylinders shall conform to the following specifications or any internationally recognised standards and be stamped to indicate such;

- (a) DOT 4B-240 (U.S Department of Transportation (DOT) specification for a welded or brazed low pressure steel gas cylinder with a service pressure rating of 240PSI);
- (b) DOT 4BA-240;
- (c) DOT 4BW-240; or
- (d) DOT 4E-240.

In cases where the above specifications are not met, a working pressure of 16.56kg/cm² (240PSI) or more shall be clearly marked by the manufacturer on the cylinder.

3.2 Cylinder markings

Cylinders shall be properly marked with the following:

- (a) tare weight;
- (b) water capacity;
- (c) serial number;
- (d) manufacturer or trade name;
- (e) date of manufacture or last test date;
- (f) tester's symbol; and
- (g) cylinder specification or working pressure.

3.3 Connections and appurtenances

Cylinders shall be fitted with the following connections and appurtenances:

- (a) safety relief device that is designed to relieve vapour;
- (b) cylinder shroud, in good condition, that is securely welded to the cylinder body, and protects the service valve. In the event that the cylinder is not fitted with a shroud (see **Figure 1**), a neck ring should be fitted onto the cylinder to allow a valve protection cap to be screwed onto the cylinder; and
- (c) foot ring, in good condition that is securely welded to the cylinder body, enables the cylinder to stand in a stable, vertical position, and prevents contact between the cylinder bottom and the ground.



Figure 1. Main parts of a LPG cylinder

GYS 264: 2025
Second Revision

NOTE 1 Clauses 3.3, 3.4, 3.5 and 3.6 are considered pre-fill criteria to be met by LPG distributors before filling cylinders.

3.4 Cylinder body

The body of the cylinder shall be in good condition, and the following shall apply:

- (a) no sharp dents or cuts;
- (b) no dents on welds;
- (c) no evidence of exposure to fire or excessive heat;
- (d) no bulging of cylinder;
- (e) no corrosion, pitting;
- (f) no general corrosion that could weaken the cylinder wall;
- (g) no damaged foot rings;
- (h) no defective or broken pins;
- (i) O ring must not have signs of cracking;
- (j) no oil or grease on valve;
- (k) no loose/slack valve; and
- (l) no dirt or any other removable substance.

3.5 Cylinder repairs

Repairs or replacement of non-pressure parts of the cylinder, such as the foot ring and neck ring, shall be done only if welding or excess heat is not applied to the pressure-bearing part of the cylinder. After repairs are completed, the cylinder shall be subjected to testing for requalification. Repairs or replacement of pressure-bearing components of cylinders shall not be performed.

3.6 Cylinder requalification

Cylinders shall be requalified periodically according to the following intervals:

- (a) every 12 years after the manufacture date, and then;
- (b) every 12 years if the previous requalification method used was the DOT water jacket type hydrostatic test; or
- (c) every 7 years, if the previous requalification method used was the DOT simple hydrostatic test.

NOTE 2 All cylinders must be subjected to a visual inspection before refilling.

3.6.1 Water jacket type hydrostatic test

A pressure of twice the marked service pressure is applied using a water jacket, so the total expansion of the cylinder during the application of the test pressure can be observed and recorded for comparison with the permanent expansion of the cylinder after depressurisation. Cylinders that pass the retest are marked with the month and year (for example, 08-06 –August, 2006). Cylinders that leak or for which the permanent expansion exceeds 10% of the total expansion shall be rejected.

3.6.2 Simple hydrostatic test

Cylinders are filled with water and a pressure of twice the marked service pressure is applied. The cylinder is carefully observed while under test pressure for leaks, swelling or bulging, to indicate weakness. Cylinders that pass the test are marked with the month and year (see **Clause 3.6.1**). Cylinders that leak, develop swelling, or bulging shall be rejected.

3.7 Storage location

Cylinders in storage shall be located in such a manner that exposure to corrosive substances or atmospheres, excessive temperature, tampering and physical damage are minimised. They shall be stored outdoors in a secure, well-ventilated environment away from doorways or openings of buildings frequented by the public. Storage of LPG cylinders shall not be below ground level, that is, in pits or basements. Escape and access routes from the premises shall not be blocked or in any way obstructed. Cylinders shall not be stored with oxidisers.

3.8 Outdoor storage

Storage shall be in cages or cabinets that are robust and capable of supporting the full weight of the cylinders to be stored. They shall be constructed of strong steel frames and provide adequate ventilation. The following requirements shall be observed:

- (a) Cages shall be positioned safely in the open air on level ground in accordance with the separation distances in **Table 1**;
- (b) If storage is in petrol stations, a separation distance of not less than 4m from petrol pumps, petrol tank man lids, vents etc. shall be observed;
- (c) Cages shall be kept locked and under direct supervision in order to deny unauthorised access;
- (d) Cages shall have the marking, “**Danger**”, “**Highly Flammable LPG**”, “**No Smoking**”, “**Open Flame**” and “**Emergency Procedures**”;
- (e) Cylinders shall be stored with their valves upright, and with the valves uppermost;
- (f) Adequate provision shall be made to prevent vehicular impact with the cage; and
- (g) All combustible materials shall be stored no less than 4m away from the cage.

3.9 Separation distances

Table 1 shows the horizontal distances away from the following areas where a quantity of LPG shall be stored:

- (a) Line of adjoining building that may be or is built upon;
- (b) Busy thoroughfares or sidewalks; and
- (c) Line of adjoining property occupied by places of public gathering.

Table 1

Table showing the quantities of LPG and the horizontal distances they can be stored

Quantity of LPG stored (kg)	Horizontal distance to a (m)	Horizontal distance to b and c (m)
0 to 325	0	0
326 to 1,135	0	3
1,136 to 2,725	3	3
2,726 to 4,540	6	6
Over 4,540	8	8

NOTE 3 For the purpose of determining the quantity of LPG stored above, all cylinders shall be considered full regardless of the quantity in them.

3.10 Indoor storage

Where cylinders are stored inside buildings, no more than 27kg LPG shall be stored. If more than 27kg are stored indoors, the building shall be constructed using a non-combustible material having a fire resistance of not less than 1 hour, and one of the following means of ventilation shall be used on the building:

- (a) mechanical ventilation that shall discharge air at a minimum rate of 0.3m^3 per minute per square meter of floor area; or
- (b) where natural ventilation is used, permanent, regularly spaced openings shall be provided at both high and low levels on the outside walls to ensure sufficient natural ventilation. These openings shall total at least 2.5% of the total roof and outside wall area.

Ventilation points shall be arranged to provide air movement as uniformly as possible and shall be provided at ground level and at high points on the wall. Ventilation shall be discharged to safe locations, which are within the separation distances specified in **Table 1**.

The following shall also apply for indoor storage:

- (i) Storage shall be at the ground floor level with at least one side of the store as the building's external wall;
- (ii) No more than 2000kg of LPG and no other flammable material shall be stored in this building;
- (iii) Where the storage area is within a building, the internal walls separating the storage area from the rest of the building shall be constructed of concrete;
- (iv) Cylinders shall not be stored within an enclosed cupboard or cabinet within a building;
- (v) LPG cylinders shall not be stored below ground level;
- (vi) Escape exits shall be provided at a clear distance of no more than 12m from any part of the building to an escape exit;
- (vii) All cylinders shall be stored upright with the pressure relief valve positioned in direct contact with the vapour space;
- (viii) The requirements for fire extinguishers shall be observed; and
- (ix) Storage area shall have the following markings: **"Danger", "Highly Flammable LPG", "No Smoking", "Open Flame" and "Emergency Procedures"**.

3.11 Cylinder stacking

Cylinders shall be stacked one on top of the other. The following shall be observed:

- (a) The shrouds must be of sufficient diameter that the stack will be stable and of sufficient height that the cylinder valves will not be damaged;
- (b) Thin pieces of wood may be used to separate the layers. These pieces of wood shall be flat and undamaged; and
- (c) Cylinders of 20kg or less shall be stacked no higher than three rows high. Cylinders ranging from 21kg to 35kg shall be stacked no more than two rows high. Cylinders greater than 35kg shall not be stacked more than one row high.

3.12 Fire extinguishers

Storage locations shall be provided with the appropriate number of extinguishers for dealing with LPG fires according to the following volumes:

- (a) less than 400kg - One 9kg BC extinguisher;
- (b) 400–5,000kg - Two 9kg BC extinguishers; and
- (c) Over 5,000kg - Two 9kg BC extinguishers plus one extra for every additional 10,000kg of LPG.

3.13 Cylinders for display

LPG cylinders that are stored for display, use and sale inside retail areas shall be subject to the following conditions:

- (a) Cylinders larger than 25kg capacity shall not be stored inside retail premises for display, use or sale; and
- (b) Only gas-free cylinders shall be stored in permanent windows or other point of sale displays.

4 Handling

When handling LPG cylinders, care shall be exercised, and the following shall be observed:

- (a) Cylinders shall not be rolled on their sides but shall be carried bodily, rolled on their foot rings or carried by properly designed mechanical handling equipment;
- (b) Cylinders shall always be handled in a manner that minimises damage to valves, foot rings, shrouds and caps.
- (c) **Cylinder filling**
 - (i) LPG cylinders shall only be filled by LPG companies which are licensed to fill.
 - (ii) Cylinder(s) belonging to a private individual or another LPG manufacturer may be filled by any other authorised LPG manufacturer with their expressed permission.

5 Transportation

In the process of transporting cylinders, the following shall be observed:

- (a) Vehicles shall not be loaded above the gross vehicle weight;
- (b) Cylinders shall be determined to be leak-free before loading them on vehicles;
- (c) All cylinders greater than 4.5kg LPG capacity shall be transported in an upright position, with the pressure relief device in direct contact with the vapour space of the cylinder;
- (d) The cargo space in which the LPG is stored shall be isolated from the driver's compartment, the engine and the exhaust system;
- (e) Cylinders shall be transported in open-bodied vehicles. Small cylinders may be transported in passenger cars up to a limit of 25kg. They shall be fastened securely in position to minimise the possibility of movement, tipping, or physical damage either to themselves or the supporting structure. The restraint used shall take into consideration movement that may arise from both braking and acceleration forces. Cylinders shall not be transported in car trunks.
- (f) Cylinders shall be stacked safely. In addition to the requirements for cylinder stacking (above), the following shall be observed:
 - (i) Stacking shall be done in such a manner that no more than $\frac{1}{4}$ of the height of the top layer of cylinders is higher than the height of the sides of the truck;

- (ii) Persons shall not be allowed to travel within the cylinder containing structure of the vehicle;
- (iii) Cylinders shall not be dropped or thrown onto or off the vehicles, or rolled horizontally along the ground, but trundled on the foot ring or moved in a properly designed wheelbarrow;
- (iv) Vehicles transporting more than 225kg LPG shall have a clearly visible sign that reads **"Danger", "Highly Flammable Gas" or "No Smoking"**;
- (v) Each vehicle shall be equipped with at least one approved portable fire extinguisher having a minimum capacity of 9kg dry chemical with a B:C rating;
- (vi) LPG cylinders shall not be transported with acetylene. However, LPG may be transported with other types of compressed gases such as oxygen, provided that a metal barrier for separation of the cylinders is used; and
- (vii) Cylinders shall not be transported via passenger aircraft. Air transportation may be allowed with approval and authorisation from the Guyana Civil Aviation Authority (GCAA).

NOTE 4 Exception: The provisions of this section do not apply to the transportation of LPG on vehicles on which LPG is used as the fuel for its propulsion.

- (g) Empty LPG cylinders shall be transported, stored and handled in the same manner as filled cylinders.

END OF DOCUMENT